

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 127/UJS/DLWQTML/2023-24

Dated:19/05/2023

It is certified that an inspection team headed by MR. RAKESH CHANDRA BAMRADA, SDO
From PHED,HARIDWAR inspected the SAI SANSKAR PUBLIC SCHOOL, NEAR BILAL MASJID
SARAI ROAD JWALAPUR,HARIDWAR on 19/05/2023, checked the water test report submitted by the
school and found that SAI SANSKAR PUBLIC SCHOOL has portable drinking water for the students and
staff of the institution and is having provision for running water in the toilets and maintaining the hygienic
sanitation condition in the school building & the campus.

As per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of 3 YEARS.

Signature with Seal: [Signature]

Name :

Designation :

Assistant Engineer of the Govt. Public Health Department
(PHED)/ Authorised officer of the Local Body Name &
Address of the Office / Department :

[Signature]
MANAGER
SAI SANSKAR PUBLIC SCHOOL

[Signature]
PRINCIPAL
SAI SANSKAR PUBLIC SCHOOL

Authorized Signatory
District Water Quality Testing/Monitoring
Laboratory,
Bachhand Jai Sansthan, Haridwar



District Level Water Quality Testing and Monitoring Laboratory
Uttarakhand Jal Sansthan, Jalkal Mayapur Haridwar

Ph (O): 0134-226360, E-mail: eeujshrd@yahoo.com



TC-9983

Page 1 of 1

Dated: 19/05/2023

Report ID: 127/UJS/DLWQTML/2023-24

TEST REPORT

Name and Address of Organization/ Customer	SAI SANSKAR PUBLIC SCHOOL ,		
Product Description (Surface Water/ Ground Water/ Drinking Water)	Ground water	Sample Description	One Water Sample collected from Sai Sanskar public school , near bilal masjid sarai road jwalapur
Reference Sample Identification:	DLWQTML/UJS/2023-23		Date of Start of Analysis: 16/05/2023 Date of End of Analysis: 17/05/2023
Date and Time of Sample Received: 16/05/2023 & 03:00 pm	Sample Collected by:		Customer

SN	Water Quality Parameters Under Chemical Scope	Results	Desirable Limit (BIS)	Permissible Limit (BIS) in the Absence of alternative source	Std. Test Method
1.	pH at 25°C	7.30	6.5 to 8.5	No Relaxation	IS 3025 Pt-11-2002
2.	Total Dissolved Solids (TDS), mg/L, Max	390	500	2000	IS 3025 Pt-16-2006
3.	Turbidity, NTU, Max	Less than 1	1	5	IS 3025 Pt-10-2006
4.	Total Alkalinity (as CaCO ₃), mg/L, Max	236	200	600	IS 3025 (Part 23): 2003
5.	Total Hardness (as CaCO ₃), mg/L, Max	264	200	600	IS 3025 (Part 21): 2002
6.	Calcium, mg/L, Max	74	75	200	IS 3025 (Part 40): 1991
7.	Magnesium, mg/L, Max	19.19	30	100	IS 3025 (Part 46): 1994
8.	Iron (as Fe), mg/L, Max	Less than 0.3	1	No Relaxation	IS 3025 (Part 53): 2003
9.	Nitrate, mg/L, Max	Less than 5	45	No Relaxation	APHA 23 RD 4500 NO3-B
10.	Sulfate, , mg/L, Max	Less than 5	200	400	IS 3025 (Part 24): 1986
11.	Floride, mg/L, Max	Less than 0.2	1.0	1.5	IS 3025 (Part 60): 2008

Remark: Above received water sample conforms to IS: 10500-2012 for drinking purpose with respect to above tests.

Bahmra
PRINCIPAL
SAI SANSKAR PUBLIC SCHOOL

End of Report

Rakesh Chandra Bamrada
MANAGER
SAI SANSKAR PUBLIC SCHOOL

19/05/23
Authorized Signatory,

District Water Quality Testing Monitoring

Laboratory,
Uttarakhand Jal Sansthan, Haridwar

- The results listed refer only to tested sample and applicable parameters.
- This certificate is not to be reproduced wholly or in parts promotional publicity or legal purpose without the permission of authority of testing laboratory.
- The samples will be destroyed after fifteen days from the date of issue of test certificate, unless otherwise agreed with customer.